



Scandiano, 01/22/2016



Messrs **Ceramica Blu srl**

Via di tiglio, 621
55065 Pieve di Compito
(LU)

Confidential Test Report N. 0163/2016 /I
on ceramic tiles defined by UNI EN 14411:2012

Our ref.num.: 16389
Date of request: 01/15/2016

Test Specimen

"Glazed paver tile 15x15 cm marked:
CRISTALLINA LUCIDA"

Source

Submitted to Laboratory by Client

Date Received

01/19/2016

Time of test execution

start: 01/22/2016 end: 01/22/2016

Test detail / method description / test procedure

" Determination of resistance to surface abrasion for glazed tiles -
Standard UNI EN ISO 10545 - 7:2000 "

The report relates only to the sample(s) tested. This report must not be reproduced in part without the written permission of Main Laboratory Sassuolo, nor used in any way as to lead to misrepresentation of the results or their implications.

Page 1 of 2

Mod. P032/1 rev.02



LAB N° 1170

Confidential Test Report N. 0163/2016 /I

Page 2 of 2

Date 01/22/2016

Ceramica Blu srl

Test specimen

"Glazed paver tile 15x15 cm marked:
CRISTALLINA LUCIDA"

DETERMINATION OF RESISTANCE TO SURFACE ABRASION
FOR GLAZED TILES
(Standard UNI EN ISO 10545 - 7:2000)

Definition: determination of the abrasion of glaze tiles by rotation of an abrasive load on the surface and assessment of the wear by means of visual comparison of abraded test specimens and non-abraded tiles.

Results

Abrasion visible at rev.: 6000

Test cleanness' stains of abraded surface: test not executed

Abrasion class: IV

Mod. P032 I rev.02



THE DIRECTOR
(M.L. Simioli)